# Elecnova

# Power Quality Products User Manual

Applied to: SFR-APF4-150/0.4M (Rack mounted)

# Safety instructions

Before installing and using the device, please read this manual carefully to better install and use this product. The device must be debugged by the manufacturer and its authorized agents, otherwise it may endanger personal safety and cause device failure. The resulting device damage is not covered by the warranty.

The device is only used for commercial and industrial users, not as a power source for any life support device.



# Grounding



When connecting the input cable, be sure to ground it reliably. The grounding of the device

must comply with local electrical codes.

# User maintainable devices



Tools are required for all internal maintenance and repair work of the device, and should be

performed by personnel who have received relevant training. Devices (including those

behind the cover) that require tools to open are not user-maintainable.

The device fully meets the safety requirements of device in the operating area. The device

and internal capacitor modules have dangerous voltages, but are not accessible to non-maintenance personnel. Since it is only possible to touch a device with dangerous voltage after opening the cover with a tool, the possibility of contact with dangerous voltage has been minimized. There will be no danger if the device is operated in accordance with the general specifications and following the steps recommended in this manual.

1 Introduction 1
1. Introduction
1.1 Overview
1.2 Model selection1
2. Technical specification
2.1 Technical parameters2
3. Installation4
3.1 Size 4
3.2 Installation requirements4
3.3 Wiring7
4. Operation
4.1 Check before running13
4.2 Testing
4.3 Stop
5.Maintenance
6. Handling of common abnormal problems18
7. Accessory List
Appendix: Communication Address Table21

# Content

## 1. Introduction

#### 1.1 Overview

Power quality products include active harmonic filters (AHF) and static var generators (SVG). The product uses an efficient power electronics topology and advanced all-digital control technology to dynamically eliminate harmonic currents and improve power factor. The device can be widely used in the following industrial fields (steel industry, metallurgy industry, mining industry, new energy industry, automotive industry), municipal field (water treatment industry, telecommunications industry, research institutes), commercial field (hospital, bank, shopping mall, schools, computer rooms, computer centers), rail transportation (electrified railways, subways).

#### 1.2 Model selection



HMI selection:



# 2. Technical specification

# 2.1 Technical parameters

	Input			
System voltage	Line voltage 400V			
System voltage	1150/			
range	115%			
Frequency	50Hz ±5%			
	Output and installation			
Capacity	1504			
specification	AUCT			
Module type	Rack Mounted			
Incoming way	Upper incoming/Back incoming			
	Performance			
Harmonics	≥90% (Within the range of the ordered capacity, and the load harmonic			
filtering rate	content is higher than 30% of the ordered capacity)			
Harmonics	$2^{nd}{}^{\sim}\!51^{st}$ harmonics ( If you need to control the harmonic order of more			
filtering range	than 25 times, you should write in the contract)			
Full response	<emc.< td=""></emc.<>			
time	31117			
Instantaneous	<100.0			
response time	210002			
Dynamic current	1.2 times the filter rated capacity output, 1min			
	Protection			
Overload	Automatic current limit at 100% rated output			
protection				
Other protection	Over-voltage protection, under-voltage protection, over-temperature			
	protection, over-current protection			
Operation mode				
Stand-alone	Stand-alone Support			
operation	Subbor			

Parallel					
operation	Conventionally support 8 sets, special requirements can be customized				
	Display and operation				
Status display	Power / Operation / Fault LED indication				
Module	Start/Stan/Dastart				
operation	Start/Stop/Restart				
НМІ	Optional 7" (Hole size 215×152mm)				
(Optional)	10" (Hole size 261×180mm)				
Communication	1 loop Modbus-RTU protocol external communication interface, Users				
	can have access to the background system through this interface or				
(RS485 Interface)	HMI port				
	Environment condition				
IP level	IP20 (customized)				
Operating					
environment	-25℃~40℃				
temperature					
Storage/					
transport	-25℃~55℃				
temperature					
Work humidity	Relative humidity 5~95%, no condensation				
Altitude	1000m and below(above 1000m, Every additional 100m / 1% derating)				
Standard	JB/T 11067-2013 Low-voltage active power filter device				

## 3. Installation

#### 3.1 Size



#### **3.2 Installation requirements**

#### 3.2.1 Installation environment

- Good ventilation, keep away from water, heat and flammable and explosive materials.
- Avoid direct sunlight.
- Avoid installation in environments with conductive dust, volatile gases, corrosive substances, and excessive salt.
- If necessary, an indoor exhaust fan should be installed to avoid an increase in room temperature. In a dusty environment, dust protection should be done.

#### 3.2.2 Unpacking

The equipment shall be placed in a storage environment that meets the requirements, and the storage time shall not exceed 3 months.

During equipment installation, the equipment shall be transported to the installation site and then the outer package shall be removed to check the following items:

1) Open the equipment package and visually inspect the appearance of the equipment. If there is any damage, please inform the carrier immediately.

2) Check whether the models of attached accessories are complete and correct according to the list of delivered accessories, and properly keep various spare parts and accessories for subsequent equipment installation, connecting cables and future maintenance.

When transporting, loading, unloading and handling equipment, appropriate precautions must be taken and appropriate manual and mechanical tools must be used to avoid damage to the equipment. If the equipment does not need to be installed immediately, be sure to store it on a solid and flat ground and follow the storage conditions listed in the technical parameters section. In this case, it is recommended to store the equipment in its original protective packaging.

#### 3.2.3 Installation spacing

AHF module adopts forced ventilation cooling system, with air inlet on the front plate and air outlet at the rear of the module. After installation, the air flow at the inlet and outlet of the equipment must flow freely. At maximum power, the air velocity is 375 M<sup>3</sup> / h<sub>o</sub>. The APF module has its own power control system, which can control the fan speed and maximum power according to the internal temperature, so as to ensure that the active filter can maintain the best performance under complex conditions. In order to ensure the performance of the equipment, we recommend to ensure that the air can flow freely at the front panel of the rack APF, there are no obstacles at the rear, and a gap of at least 300 mm is left.



3.2.4 Installation in cabinet



The rack type installation in the cabinet is shown in the figure. Pay attention to the heat dissipation design in the cabinet

#### 3.3 Wiring



#### Function interface definition

Port type	Port	Function/description				
X1	OUT	Output communication with other modules via network				
Х2	IN	Communicate with HMI touch screen through network cable or online with the previous module				
Х3	A1					
Communication	B1	Communication output				
port	G1					
X4	L1-S1	Input port of phase a current detection S1 (connected with phase a transformer S1)				
CT signal port	L1-S2	Phase a current detection S2 input port (connected with phase a transformer S2)				

	L2-S1	Phase B current detection S1 input port (connected with phase B transformer S1)				
	L2-S2	Phase B current detection S2 input port (connected with phase B transformer S2)				
	L3-S1	Phase C current detection S1 input port (connected with phase C transformer S1)				
	L3-S2	Phase C current detection S2 input port (connected with phase C transformer S2)				
	DO1	Programmable relay output, default configuration				
	N1	equipment fault relay output				
	DO2	Programmable relay output. The default configuration is the				
X5	N2	relay output for equipment startup and operation				
Control signal	DI1	Equipment emergency stop input port (connected with				
port	С	external "normally closed" emergency stop button)				
	0V	Power output negative pole 0V (supplying power to HMI touch screen)				
	24V	Power output positive + 24V (supplying power to HMI touch screen)				

#### 3.3.1 Power cable selection

#### Table 3-1 Recommended section of cable cross section

Current	ABC three phase main circuit incoming	N line	PE line
capacity	line selection	selection	selection
50A and	Copper core is 25 mm2 insulated	The N-line	
below	heat-resistant flexible cable	cable is 1.5	
704 1204	Copper core is 50 mm2 insulated	times the	The PE cable
70A-120A	heat-resistant flexible cable	copper core	is 0.67 times
1204 1604	Copper core is 70 mm2 insulated	of the	the copper
120A-100A	heat-resistant flexible cable	three-phase	core of the
	Copper core is 90 mm2(or 2 pcs of	ABC main	three-phase
160A-220A	50mm2) insulated heat-resistant flexible	circuit cable.	ABC main
	cable	(Note: 3L AHF	circuit cable
2204 2004	Copper core is 120 mm2(or 2 pcs of	in the	
220A-300A	70mm2) insulated heat-resistant flexible	specification	

	cable	model has no	
300A-400A	Copper core is 2 pcs of 90mm2 insulated heat-resistant flexible cable	N line; 4L AHF	
		in the	
		specification	
		model has N	
		line)	

The device power input and output power cables mainly include the main AC power input cable and the protective ground wire. It is recommended that the input and output cables of the device should be BVR or RV type flexible connecting cables with a rated dielectric strength of AC450V / 750V and an operating temperature of 70 ° C. The current and cable selection of this device are shown in Table 3-1.

#### 3.3.2 CT and its cable selection

The use of current transformer is mainly used for AHF to collect load current and calculate the data of harmonic current, reactive current, negative sequence current and zero sequence current of load current. Table 3-2 is the selection guide for the key parameters of transformers used in this series of AHFs.

Parameter	Requirements	Remarks
Primary rated current	In	Recommend: 0.3In≤Actual maximum operating current≤0.6In
Secondary rated current	5A	
Rated voltage	≥0.66kV	
Rated capacity	≥2VA	
Accuracy level	0.5 or 0.2	
Dimension		The specific size needs to be selected according to the on-site installation environment

Table 3-2 Transformer key parameter selection

Transformer secondary side (rated current 5A) cable, a total of 3 groups (6 pcs)

below 15m : RVVSP 2 × 2.5  $mm^2$  ; 15m-30m: RVVSP 2 × 4  $mm^2$ .

Note: if the load current is too small, the compensation and filtering effect may be affected. Please know!

#### 3.3.3 Cable connections

Notes:

- To ensure safety, make sure that the power supply device (such as a transformer) is powered off before connecting all cables;
- To ensure safety, first connect the ground wire;
- Make sure the phase sequence of power cable connection is correct;

• Adopt the correct power distribution method (see Figure 3-3A and Figure 3-3B) to ensure the safety of AHF and user device; The main circuit wiring mode is shown in the figure. The wiring should ensure that the phase sequence of the power grid is consistent with the phase sequence of the device. Otherwise, the device may not start normally. The installation direction of the transformer must be close to the load as shown on the P2 surface. The S1 and S2 of each transformer must correspond to the AHF port with the corresponding label. It is strictly forbidden to open the secondary side.(If the circuit is open, it may cause the transformer to burn).



Figure 3-3A

Correct power distribution mode (the transformer is located behind the PCC point). At this time, the CT configuration shall be "load side"



Figure 3-3B

Correct power distribution mode (transformer is located in front of PCC point).

At this time, CT configuration shall be "grid side"

Important: when the module is APF, if there is a reactive power compensation cabinet on site, the transformer cannot contain the current of the reactive power compensation

cabinet, otherwise the module will not operate normally or even be damaged!



Figure 3-4 CT connection diagram of multiple modules



Figure .3-5 schematic diagram of connection of multiple modules and machine communication lines

When multiple modules are combined, CT\_B/CT\_C. refer to CT for signal wiring mode\_A (Fig. 3-4), the current signals are connected in series. The communication interfaces X1 and X2 of the module are connected hand in hand through the network cable (Fig. 3-5), and finally connected with the man-machine interface through the connecting line of DB9 network port.

# 4. Operation

#### 4.1 Check before running

After the installation of the device, power on after confirming the electrical connection of the system.

1) Confirm that the device shell is reliably connected with the protective ground to prevent the shell from being charged.

2) Check and confirm that the power distribution mode of the device, power cables and signal cables are correctly connected without short circuit.

3) Check and confirm that all input switches are disconnected, and put warning signs on these switches to prevent other faults people operate the switch.

#### 4.2 Testing

(1) Setting parameters: the required parameters are transformation ratio of current transformer, CT position, shunt coefficient and number of parallel units.

Name	Description	Range	Remark		
Transformation	Sampling CT ratio	0~20000	Set up according to the		
ratio			site conditions		
Shunt	Reciprocal of number of	0~1000	Ratio of module to total		
coefficient	parallel machines	0,~1.000	parallel operation capacity		
Threshold current	When the load current exceeds the threshold current setting value, the devicce operates without load and does not output compensation current	0~100	Set according to site conditions The default is 0		
Unbalance threshold	When the load current exceeds the threshold current setting value, the equipment operates without load and does not output compensation	0~100	Set according to site conditions The default is 0		

	current		
Total current limiting	Output maximum current	0~150	The total current limit shall not exceed the rated current of the module
Number of parallel machines	Number of parallel operation modules	1~8	
Temperature limit	Temperature limit protection switch	Start/Stop	When on, derate the total current when the internal heat dissipation temperature exceeds the default value
CT position	Select the transformer location	Load or grid	1: Grid side 2: Load side
Postal address	External communication address	1~243	
Baud rate	Baud rate of external communication	2400 ~ 38400	Default 9600
Data format	Data format of external communication		N.8.1
Power factor	Set target power factor	0.9~1	Factory Setting 0.98

(2) In the function option setting, you can select the number of harmonics to be filtered. It is recommended that 3, 5, 7 and 11 be turned on and the rest be turned off.

(3) To start up, click the start slider on the touch screen or long press the "start" button of the module.

(4) Use the power quality analyzer or the multi-function meter with harmonic measurement on the incoming cabinet to observe whether the current harmonic content decreases. If it does not decrease, it increases. It is necessary to detect whether the wiring and position of the current transformer are correct.

Note: please refer to the man-machine interface user manual for detailed operation.

#### 4.3 Stop

[1] Click the touch screen shutdown slider or long press the "Stop" button of the module.

[2] Disconnect the MCCB.



About 15 minutes after the complete power off, the electrolytic capacitor voltage inside the device is completely released, and the device is shut down normally. Pay attention to personal safety to prevent electric shock !

#### 5.Maintenance

The components inside the device are stationary except for the cooling fan rotating. Routine maintenance content is very small, because the normal operation of the device is greatly affected by the environment, so in daily maintenance, care must be taken to ensure that the environmental requirements for device operation are met. It is recommended that the user record the following inspection contents, so that the machine can maintain the best performance and prevent small problems from turning into major failures.

#### 1.Daily inspection

1) Check whether the panel running indicator is on;

2) Check that there is no obvious high temperature at the output of each fan in the cabinet;

3) Whether there is abnormal noise and abnormal smell;

4) Confirm that the ventilation grid is not blocked;

5) Check whether all fans are operating normally and confirm that there is wind blowing out from the machine. The life of the fan will be shortened under high temperature environment;

6) Measure and record the three-phase input voltage of the device;

7) Measure and record the current of each phase of the device input. If the measured value is significantly different from the previous one, record the size, type and location of the newly added load, which is helpful to help analyze whether a failure will occur.

#### 2. Monthly inspection

1) First check according to the content of daily inspection;

2) Shut down according to the shutdown procedure, wait 10 minutes, and then check when the DC side capacitor voltage drops to a safe voltage;

3) Check the aging, wear and over temperature traces of power cables and signal cables, and check whether the power cables and signal cables are firmly connected;

4) Use a vacuum cleaner to remove surface impurities, and use low-pressure air to remove the dust from the cooling air duct to keep the air duct clear.

#### 3. Other checks

1)Input / output cable insulation jacket and connection end inspection: periodic inspection is recommended. At this time, the device needs to be completely powered off, and the inspection period is preferably not more than 1 year;

# 6. Handling of common abnormal problems

When the device stops during operation, the abnormal information will be saved in the event record, and the user can analyze and deal with it according to the saved fault information.

Serial	Problem	Cause Analysis	Approach		
number 1	Description The active power of the touch screen view interface is negative	The current direction of the L1 transformer, or its secondary signal line is reversed, or the three-phase current and the three-phase voltage	Check if the current direction of L1 transformer is from P1 to P2? S1 is connected to terminal block L1-1, S2 is connected to terminal block L1-2? Check the sequence of three-phase		
		are not in one-to-one correspondence;	correspondence?		
2	Start-up emergency stop protection	The emergency stop button is pressed, or the module DI1 port and port C are not short-circuited;	If the emergency stop button is pressed, release the emergency stop button; if there is no emergency stop button, and port DI1 and port C are not short-circuited, short-circuit with a wire.		
3	The fan does not rotate after the device is started	Fan failure: abnormal 24V power supply; missing fan control signal;	Check whether the fan cable is disconnected; check whether the fan is damaged (such as fan motor failure); check whether the 24V power supply is normal;		
4	The power factor is low	Insufficient reactive power compensation capacity; Device	Check whether the wiring of main cable and transformer signal line is wrong; Measure and compare the		

Table 6.1 Problems and treatment of field installation wiring debugging

		wiring error;	power	factor	during	equipment
			operatio	n and sh	utdown t	o determine
			whether	the	reactiv	ve power
			compens	sation ca	pacity is i	nsufficient;
1) In the case of load current, the secondary side of the transformer cannot be opened,						
otherwise the transformer may be damaged, so the secondary side needs to be shorted						
with a shorting piece.						

# 7. Accessory List

1. Dimensions		581mm(Width)×230mm(Height)×729mm(Depth)						
2. Weight		51kg						
3. Accessorie	es							
No.		Name	Specification	Quantity				
1	R	ack mount		2				
2		Terminal	8P	1(already installed on the product)				
3		Terminal	6P	1(already installed on the product)				
4		Terminal	ЗР	1(already installed on the product)				
5	В	ridge piece	EBL2-5	1(already installed on the product)				
6	Cr cou	oss recessed ntersunk head screws	M4×8	6				
7	Cros h	s recessed pan lead screws	M6×12	4				
8	Te	sting record		1				
9	I	nstruction	User Manual for Power Quality Products	1				

# Appendix: Communication Address Table

Ac	ldress	R/W	Data	Data	Namo	Description
Hex.	Decimal	type	type	format	Name	Description
0x0	0	R/W	long	D*1	Run_ST	Protection mark
0.2	2	D	long	D*1	Filter	Harmonic enable flag (display 0 means
0.12	2	n	long		Flag	off, display 1 means on)
0v4	л	R	long	ר*ח	PH En Flag	Imbalance enable flag (display 0
0,4	-		long			means off, display 1 means on)
0v6	6	R	long	D*1	O En Elag	Reactive enable flag (display 0 means
		Ň	iong			off, display 1 means on)
0x8	8	R	long	D*1	Auto_Reset	Self-reset enable flag (display 0 means
			iong		Flag	off, display 1 means on)
ΟνΔ	10	R	long	D*1	On_Off	Start flag (display 0 means off, display
	10	Ň	IONS		Flag	1 means on)
0xC	12	R	long	D*0.01	DC+	DC bus upper side voltage xxxx.xxV
0xE	14	R	long	D*0.01	DC-	DC bus lower voltage xxxx.xxV
0x10	16	R	long	D*0.01	DC	DC bus total voltage xxxx.xxV
0x12	18	R	long	D*0.01	la_Out	Device L1 output current value xxx.xxA
0x14	20	R	long	D*0.01	lb_Out	Device L2 output current value xxx.xxA
0x16	22	R	long	D*0.01	lc_Out	Device L3 output current value xxx.xxA
0x18	24	R	long	D*0.01	In_Out	Device LN output current value xxx.xxA
0x1A	26	R	long	D*0.01	Uan	Phase L1 grid side voltage xxx.xxV
0x1C	28	R	long	D*0.01	Ubn	Phase L2 grid side voltage xxx.xxV
0x1E	30	R	long	D*0.01	Ucn	Phase L3 grid side voltage xxx.xxV
0x20	32	R	long	D*0.01	la	Phase L1 grid side current xxx.xxA
0x22	34	R	long	D*0.01	Ib	Phase L2 grid side current xxx.xxA
0x24	36	R	long	D*0.01	lc	Phase L3 grid side current xxx.xxA
0x26	38	R	long	D*0.01	In	Phase LN grid side current xxx.xxA

0x28	40	R	long	D*0.01	Pa_Sys	Phase L1 grid side active power xxx.xxkw
0x2A	42	R	long	D*0.01	Pb_Sys	Phase L2 grid side active power xxx.xxkw
0x2C	44	R	long	D*0.01	Pc_Sys	Phase L3 grid side active power xxx.xxkw
0x2E	46	R	long	D*0.01	P_Sys	Grid side active power xxx.xxkw
0x30	48	R	long	D*0.01	Qa_Sys	Phase L1 grid side reactive power
0x32	50	R	long	D*0.01	Qb_Sys	Phase L2 grid side reactive power
0x34	52	R	long	D*0.01	Qc_Sys	Phase L3 grid side reactive power
0x36	54	R	long	D*0.01	Q_Sys	Grid side reactive power
0x38	56	R	long	D*0.01	Sa_Sys	Phase L1 grid side apparent power
0x3A	58	R	long	D*0.01	Sb_Sys	Phase L2 grid side apparent power
0x3C	60	R	long	D*0.01	Sc_Sys	Phase L3 grid side apparent power
0x3E	62	R	long	D*0.01	S_Sys	Grid side apparent power
0x40	64	R	long	D*0.001	Pfa_Sys	Phase L1 grid side power factor
0x42	66	R	long	D*0.001	Pfb_Sys	Phase L2 grid side power factor
0x44	68	R	long	D*0.001	Pfc_Sys	Phase L3 grid side power factor
0x46	70	R	long	D*0.001	Pf	Grid side power factor xxx.x
0x48	72	R	long	D*0.01	Thd_Sys	Grid side current harmonics distortion rate xxx.xx%
0x4A	74	R	long	D*0.01	SysUnbalance	Grid side current imbalance rate
0x4C	76	R	long	D*0.01	la_Load	Load side current L1
0x4E	78	R	long	D*0.01	lb_Load	Load side current L2
0x50	80	R	long	D*0.01	lc_Load	Load side current L3
0x52	82	R	long	D*0.01	In_Load	Load side current LN
0x54	84	R	long	D*0.01	LoadUnbalan	Load side current imbalance rate
0x56	86	R	long	D*0.01	la_LCL	Phase L1 capacitor filter current xxx.xx

0x58	88	R	long	D*0.01	lb_LCL	Phase L2 capacitor filter current xxx.xx
0x5A	90	R	long	D*0.01	Ic_LCL	Phase L3 capacitor filter current xxx.xx
0x5C	92	R	long	D*0.01	In_LCL	Phase LN capacitor filter current xxx.xx
0x5E	94	R	long	D*0.1	Tem_A1	IGBT L1 phase temperature *0.1
0x60	96	R	long	D*0.1	Tem_B1	IGBT L2 phase temperature*0.1
0x62	98	R	long	D*0.1	Tem_C1	IGBT L3 phase temperature*0.1
0x64	100	R	long	D*0.1	Tem_A2	IGBT L1 phase temperature *0.1
0x66	102	R	long	D*0.1	Tem_B2	IGBT L2 phase temperature*0.1
0x68	104	R	long	D*0.1	Tem_C2	IGBT L3 phase temperature*0.1
0x6A	106	R	long	D*0.01	THI02	2 <sup>nd</sup> harmonic current calculation percentage XXX.XX%
0x6C	108	R	long	D*0.01	THI03	3 <sup>rd</sup> harmonic current calculation percentage
0x6E	110	R	long	D*0.01	THI04	4 <sup>th</sup> harmonic current calculation percentage
0x70	112	R	long	D*0.01	THI05	5 <sup>th</sup> harmonic current calculation percentage
0x72	114	R	long	D*0.01	THI06	6 <sup>th</sup> harmonic current calculation percentage
0x74	116	R	long	D*0.01	THI07	7 <sup>th</sup> harmonic current calculation percentage
0x76	118	R	long	D*0.01	THI08	8 <sup>th</sup> harmonic current calculation percentage
0x78	120	R	long	D*0.01	THI09	9 <sup>th</sup> harmonic current calculation percentage
0x7A	122	R	long	D*0.01	THI10	10 <sup>th</sup> harmonic current calculation percentage

0x7C	124	R	long	D*0.01	THI11	11 <sup>th</sup> harmonic current calculation percentage
0x7E	126	R	long	D*0.01	THI12	12 <sup>th</sup> harmonic current calculation percentage
0x80	128	R	long	D*0.01	THI13	13 <sup>th</sup> harmonic current calculation percentage
0x82	130	R	long	D*0.01	THI14	14 <sup>th</sup> harmonic current calculation percentage
0x84	132	R	long	D*0.01	THI15	15 <sup>th</sup> harmonic current calculation percentage
0x86	134	R	long	D*0.01	THI16	16 <sup>th</sup> harmonic current calculation percentage
0x88	136	R	long	D*0.01	THI17	17 <sup>th</sup> harmonic current calculation percentage
0x8A	138	R	long	D*0.01	THI18	18 <sup>th</sup> harmonic current calculation percentage
0x8C	140	R	long	D*0.01	THI19	19 <sup>th</sup> harmonic current calculation percentage
0x8E	142	R	long	D*0.01	THI20	20 <sup>th</sup> harmonic current calculation percentage
0x90	144	R	long	D*0.01	THI21	21 <sup>st</sup> harmonic current calculation percentage
0x92	146	R	long	D*0.01	THI22	22 <sup>nd</sup> harmonic current calculation percentage
0x94	148	R	long	D*0.01	THI23	23 <sup>rd</sup> harmonic current calculation percentage
0x96	150	R	long	D*0.01	THI24	24 <sup>th</sup> harmonic current calculation percentage
0x98	152	R	long	D*0.01	THI25	25 <sup>th</sup> harmonic current calculation percentage

0x9A	154	R	long	D*0.01	THI02_Load	2 <sup>nd</sup> harmonic current calculation percentage XXX.XX%
0x9C	156	R	long	D*0.01	THI03_Load	3 <sup>rd</sup> harmonic current calculation percentage
0x9E	158	R	long	D*0.01	THI04_Load	4 <sup>th</sup> harmonic current calculation percentage
0xA0	160	R	long	D*0.01	THI05_Load	5 <sup>th</sup> harmonic current calculation percentage
0xA2	162	R	long	D*0.01	THI06_Load	6 <sup>th</sup> harmonic current calculation percentage
0xA4	164	R	long	D*0.01	THI07_Load	7 <sup>th</sup> harmonic current calculation percentage
0xA6	166	R	long	D*0.01	THI08_Load	8 <sup>th</sup> harmonic current calculation percentage
0xA8	168	R	long	D*0.01	THI09_Load	9 <sup>th</sup> harmonic current calculation percentage
0xAA	170	R	long	D*0.01	THI10_Load	10 <sup>th</sup> harmonic current calculation percentage
0xAC	172	R	long	D*0.01	THI11_Load	11 <sup>th</sup> harmonic current calculation percentage
0xAE	174	R	long	D*0.01	THI12_Load	12 <sup>th</sup> harmonic current calculation percentage
0xB0	176	R	long	D*0.01	THI13_Load	13 <sup>th</sup> harmonic current calculation percentage
0xB2	178	R	long	D*0.01	THI14_Load	14 <sup>th</sup> harmonic current calculation percentage
0xB4	180	R	long	D*0.01	THI15_Load	15 <sup>th</sup> harmonic current calculation percentage
0xB6	182	R	long	D*0.01	THI16_Load	16 <sup>th</sup> harmonic current calculation percentage

0xB8	184	R	long	D*0.01	THI17_Load	17 <sup>th</sup> harmonic current calculation percentage
0xBA	186	R	long	D*0.01	THI18_Load	18 <sup>th</sup> harmonic current calculation percentage
0xBC	188	R	long	D*0.01	THI19_Load	19 <sup>th</sup> harmonic current calculation percentage
OxBE	190	R	long	D*0.01	THI20_Load	20 <sup>th</sup> harmonic current calculation percentage
0xC0	192	R	long	D*0.01	THI21_Load	21 <sup>st</sup> harmonic current calculation percentage
0xC2	194	R	long	D*0.01	THI22_Load	22 <sup>nd</sup> harmonic current calculation percentage
0xC4	196	R	long	D*0.01	THI23_Load	23 <sup>rd</sup> harmonic current calculation percentage
0xC6	198	R	long	D*0.01	THI24_Load	24 <sup>th</sup> harmonic current calculation percentage
0xC8	200	R	long	D*0.01	THI25_Load	25 <sup>th</sup> harmonic current calculation percentage
0xCA	202	R	long	D*0.01	IA1_OUT	L1-1 phase output current value xxx.xxxa
0xCC	204	R	long	D*0.01	IB1_OUT	L2-1 phase output current value xxx.xxxa
0xCE	206	R	long	D*0.01	IC1_OUT	L3-1 phase output current value xxx.xxxa
0xD0	208	R	long	D*0.01	IA2_OUT	L1-2 phase output current value xxx.xxxa
0xD2	210	R	long	D*0.01	IB2_OUT	L2-2 phase output current value xxx.xxxa
0xD4	212	R	long	D*0.01	IC2_OUT	L3-2phase output current value xxx.xxxa

0xD5	213	R	int	D*0.1	Temp_In	Internal temperature
0xD6	214	R	int	D*0.1	Temp_Fan	Outside temperature

#### **Protection mark**

The 0 <sup>th</sup>	DC bus over-voltage protection	The 7 <sup>th</sup>	DC bus under-voltage protection
The 1 <sup>st</sup>	AC grid over-voltage protection	The 8 <sup>th</sup>	LCL topology C branch overload protection
The 2 <sup>nd</sup>	AC grid under-voltage protection	The 9 <sup>th</sup>	Grid voltage Ud off-limit protection
The 3 <sup>rd</sup>	Contactor abnormal protection	The 10 <sup>th</sup>	Grid voltage sum off-limit protection
The 4 <sup>th</sup>	Module IGBT over-temperature protection	The 11 <sup>th</sup>	AC grid voltage phase loss protection
The 5 <sup>th</sup>	Module output over-current protection	The 12 <sup>th</sup>	Null
The 6 <sup>th</sup>	Module emergency stop protection		

The information in this document is subject to changes without any further notice.